



WRAS PRODUCT APPROVAL CERTIFICATE

Approval Number
250702033

Field of application	Products complying with the Water Supply (Water Fittings) Regulations 1999 (England & Wales), the Water Supply (Water Fittings) (Scotland) Byelaws 2014 and the Water Supply (Water Fittings) Regulations (Northern Ireland) 2009.
Approval holder	Neoperl GmbH
WRAS directory section	1860
Product type	Tubes
Model	SOFTPEX® 39.00CD.EFG.HI RANGE OF BRAIDED HOSES
Basis of compliance	Tested to regulators Specification Test Code Sheets
Valid from	1st July 2025
Date of expiry	31st July 2030
Authorised by	 Ian Hughes, WRAS Approvals Manager



The certificate by itself is not evidence of a valid WRAS Approval.
The certificate must always be shared with the supporting letter.
Confirmation of the current status of an approval must be obtained from
the WRAS Approvals Directory (www.wrasapprovals.co.uk/directory/)



Certificate issued: 29th July 2025



29th July 2025

Neoperl GmbH
Klosterrunstrasse 9-11,
Müllheim,
Germany
D-79379

Water Regulations Approval Scheme Ltd
Unit 13, Willow Road
Pen y Fan Industrial Estate
Crumlin
Gwent
NP11 4EG

Approval Number 250702033

Dear Sir/Madam

Production samples of the products described in the **Approval Information** section below ("Products"), have been subjected to the relevant mechanical and water quality tests as defined in Regulation 4 (2) and Schedule 2 to demonstrate a product is of an **appropriate quality or standard** for the purposes of a WRAS Approval application.

1. After considering the test reports and examining the Product/s, The Water Regulations Approval Scheme Ltd. ("WRAS Ltd" / "WRAS") finds that:

The product is of an appropriate quality and standard as defined in The Water Supply (Water Fittings) Regulations 1999, The Water Supply (Water Fittings) (Scotland) Byelaws 2014, The Water Supply (Water Fittings) Regulations (Northern Ireland) 2009 and all other applicable WRAS requirements,

The non-metallic materials of construction, in contact with the water, are suitable for contact with wholesome water intended for domestic purposes having met the requirements of BS 6920-1: 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

2. WRAS Approvals are granted subject to, and in accordance with, the Standard Terms and Conditions of WRAS Approvals Schemes (WRAS.Cust-401) as amended from time to time ("Standard Terms of Approval").

You have confirmed your acceptance of the Standard Terms of Approval by submitting your application for WRAS Approval. A copy of the current Standard Terms of Approval are available from the [WRAS website](#).

Terms defined in the Standard Terms of Approval shall have the same meaning in this letter unless the context otherwise requires.

3. Installation Requirements & Notes (IRNs) are set out in Appendix A. A Product only qualifies for Approval if WRAS is satisfied that the relevant Product complies with Regulation 4(1)(a) and the requirements of the Scheme when installed in accordance with the manufacturer's instructions and any applicable Approval Scheme Installation Requirements and Notes.

Since the incorrect installation of Products will not be within the scope of an approval and may result in contravention of the Regulations or Byelaws requirements, **the attention of your customers should be drawn to any IRNs applied.**

4. Please note that the use of the Products described in any particular area of supply is at the discretion of the Water Company (water undertaker) in that area.
5. Approval Holders may quote in their sales literature that their product is WRAS approved. A WRAS product approval demonstrates that a water fitting is of a suitable quality and standard, provided that it meets the requirements of the Scheme when installed in accordance with the manufacturer's instructions and any applicable Approval Scheme Installation Requirements and Notes
6. The "WRAS Approved Product" logos are certification marks registered under the Trade Marks Act 1994 ("Certification Marks"). Approval Holders may use the Certification Marks in accordance with the Standard Terms of Approval.
7. Please verify the details of your Product as set out in the approval information and advise us of any discrepancies by no later than **29th August 2025**.

Yours Faithfully

Ian Hughes
WRAS Approvals Manager

APPROVAL INFORMATION

Validity dates:	This approval is valid for fittings (as listed below in model) manufactured AND installed between July 2025 & July 2030
Section Number:	1860 TUBES
Section title:	TUBES PLASTIC HOSES.
Installation requirement notes:	R001, R008 (IRN's are set out in Appendix A)
Product description:	Softpex® Range of Stainless Steel and Polyamide braided, PE lined connection hoses with various end connections DN6 (S/S & PA braided – PE-RT) , DN8 (S/S & PA braided – PEX), DN10 (S/S braided - PEX ONLY), DN13 (S/S braided - PEX ONLY) Maximum working pressure; 10 Bar Maximum operating temperature; 70°C
Size:	Female elbow (BSP) ¾, ½, ¼ Female straight (BSP) ¾, ½, ¼ Tube ø10, ø12 & ø15 Male M8, M10, M12 Male straight (BSP)- ¾, ½, ¼ Comp. joint (Compression)- ø10
Identification Marking:	Neoperl, SPX, size, temperature, date of manufacture (YYMMDD) on ferrule
Approval Holder:	Neoperl GmbH
Model:	Softpex® 39.00CD.EFG.HI Part Code nomenclature constructed in the following manner: - 39.ABCD.EFG.HI A = Hose Type (supply hose, outlet hose, shower hose etc.) B = Hose (inliner) Material CD.EFG = Manufacturing sequential number HI = Packaging information DN6 (S/S & PA braided - PEX & PE-RT) DN8 (S/S & PA braided - PEX & PE-RT) DN10 (S/S braided - PEX ONLY) DN13 (S/S braided - PEX ONLY)

APPENDIX A

INSTALLATION REQUIREMENTS & NOTES

You are advised to draw customers' attention to the installation requirements and notes set out below which must be followed to ensure that the fittings described above are installed in accordance with the requirements of the Regulations and Byelaws:

IRN R001

See text of entry for Installation Requirements or Notes.

IRN R008

This fitting is to be installed where light is excluded.